


BSP Consulting		Page 1
12 Oxford Street Nottingham NG1 5BG	22-0364 Former Woodland Hotel Haverhill	
Date 30/01/2024 File 240125_Surface Water Cal...	Designed by FE Checked by PN	
Innovyze	Network 2020.1.3	

STORM SEWER DESIGN by the Modified Rational Method

Design Criteria for Storm

Pipe Sizes STANDARD Manhole Sizes STANDARD

FSR Rainfall Model - England and Wales

Return Period (years)	100	PIMP (%)	100
M5-60 (mm)	20.800	Add Flow / Climate Change (%)	0
Ratio R	0.418	Minimum Backdrop Height (m)	0.200
Maximum Rainfall (mm/hr)	50	Maximum Backdrop Height (m)	1.500
Maximum Time of Concentration (mins)	30	Min Design Depth for Optimisation (m)	1.200
Foul Sewage (l/s/ha)	0.000	Min Vel for Auto Design only (m/s)	1.00
Volumetric Runoff Coeff.	0.750	Min Slope for Optimisation (1:X)	500

Designed with Level Soffits

Time Area Diagram for Storm




Time (mins)	Area (ha)	Time (mins)	Area (ha)
0-4	0.158	4-8	0.232

Total Area Contributing (ha) = 0.390

Total Pipe Volume (m³) = 11.802


Network Design Table for Storm

« - Indicates pipe capacity < flow















PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
1.000	36.174	2.310	15.7	0.035	5.00	0.0	0.600	o	150	Pipe/Conduit	
1.001	5.103	0.190	26.9	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
1.002	37.358	1.480	25.2	0.035	0.00	0.0	0.600	o	225	Pipe/Conduit	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
1.000	50.00	5.24	73.350	0.035	0.0	0.0	0.0	2.56	45.2	4.7
1.001	50.00	5.28	71.040	0.035	0.0	0.0	0.0	1.95	34.5	4.7
1.002	50.00	5.52	70.775	0.070	0.0	0.0	0.0	2.61	104.0	9.5


BSP Consulting		Page 2
12 Oxford Street Nottingham NG1 5BG	22-0364 Former Woodland Hotel Haverhill	
Date 30/01/2024 File 240125_Surface Water Cal...	Designed by FE Checked by PN	
Innovyze	Network 2020.1.3	

Network Design Table for Storm








PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
1.003	8.066	0.240	33.6	0.000	0.00	0.0	0.600	o	225	Pipe/Conduit	
1.004	33.097	0.972	34.1	0.058	0.00	0.0	0.600	o	225	Pipe/Conduit	
2.000	13.709	0.343	40.0	0.016	5.00	0.0	0.600	o	150	Pipe/Conduit	
2.001	10.042	0.251	40.0	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
2.002	26.587	0.470	56.6	0.052	0.00	0.0	0.600	o	225	Pipe/Conduit	
2.003	8.532	0.853	10.0	0.000	0.00	0.0	0.600	o	225	Pipe/Conduit	
2.004	4.987	0.033	151.1	0.000	0.00	0.0	0.600	o	225	Pipe/Conduit	
2.005	31.170	1.528	20.4	0.017	0.00	0.0	0.600	o	225	Pipe/Conduit	
3.000	7.263	0.048	151.3	0.064	5.00	0.0	0.600	o	150	Pipe/Conduit	
2.006	8.558	0.108	79.2	0.007	0.00	0.0	0.600	o	225	Pipe/Conduit	
2.007	9.647	0.536	18.0	0.008	0.00	0.0	0.600	o	225	Pipe/Conduit	
1.005	8.334	0.833	10.0	0.000	0.00	0.0	0.600	o	225	Pipe/Conduit	
4.000	3.384	0.338	10.0	0.048	5.00	0.0	0.600	o	150	Pipe/Conduit	
5.000	13.328	0.355	37.5	0.036	5.00	0.0	0.600	o	150	Pipe/Conduit	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
1.003	50.00	5.58	69.295	0.070	0.0	0.0	0.0	2.26	90.0	9.5
1.004	50.00	5.82	69.055	0.128	0.0	0.0	0.0	2.25	89.4	17.3
2.000	50.00	5.14	73.640	0.016	0.0	0.0	0.0	1.60	28.2	2.2
2.001	50.00	5.25	73.297	0.016	0.0	0.0	0.0	1.60	28.2	2.2
2.002	50.00	5.50	72.971	0.068	0.0	0.0	0.0	1.74	69.3	9.2
2.003	50.00	5.54	72.501	0.068	0.0	0.0	0.0	4.16	165.5	9.2
2.004	50.00	5.61	70.157	0.068	0.0	0.0	0.0	1.06	42.2	9.2
2.005	50.00	5.79	70.255	0.085	0.0	0.0	0.0	2.91	115.7	11.5
3.000	50.00	5.15	68.850	0.064	0.0	0.0	0.0	0.81	14.4	8.7
2.006	50.00	5.89	68.727	0.156	0.0	0.0	0.0	1.47	58.5	21.1
2.007	50.00	5.94	68.619	0.164	0.0	0.0	0.0	3.10	123.2	22.2
1.005	50.00	5.98	68.083	0.292	0.0	0.0	0.0	4.16	165.5	39.5
4.000	50.00	5.02	67.663	0.048	0.0	0.0	0.0	3.20	56.6	6.5
5.000	50.00	5.13	67.680	0.036	0.0	0.0	0.0	1.65	29.1	4.9

BSP Consulting		Page 3
12 Oxford Street Nottingham NG1 5BG	22-0364 Former Woodland Hotel Haverhill	
Date 30/01/2024 File 240125_Surface Water Cal...	Designed by FE Checked by PN	
Innovyze	Network 2020.1.3	

Network Design Table for Storm

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
1.006	8.929	0.090	99.2	0.000	0.00	0.0	0.600	o	225	Pipe/Conduit	
1.007	8.470	0.435	19.5	0.014	0.00	0.0	0.600	o	150	Pipe/Conduit	
1.008	4.738	0.200	23.7	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
1.009	7.874	0.550	14.3	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
1.010	51.643	2.850	18.1	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
1.011	50.114	2.338	21.4	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
1.012	39.177	0.262	149.5	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
1.006	50.00	6.09	66.275	0.376	0.0	0.0	0.0	1.31	52.2	50.9
1.007	50.00	6.15	66.185	0.390	0.0	0.0	0.0	2.29	40.5<	52.8
1.008	50.00	6.19	65.750	0.390	0.0	0.0	0.0	2.08	36.7<	52.8
1.009	50.00	6.24	65.550	0.390	0.0	0.0	0.0	2.68	47.3<	52.8
1.010	50.00	6.60	65.000	0.390	0.0	0.0	0.0	2.38	42.0<	52.8
1.011	50.00	6.98	62.150	0.390	0.0	0.0	0.0	2.18	38.6<	52.8
1.012	50.00	7.78	59.810	0.390	0.0	0.0	0.0	0.82	14.5<	52.8

Free Flowing Outfall Details for Storm


Outfall Pipe Number	Outfall C. Level Name (m)	I. Level (m)	Min I. Level (m)	D,L (mm)	W (mm)
1.012	60.600	59.548	0.000	0	0

Simulation Criteria for Storm

Volumetric Runoff Coeff	0.750	Additional Flow - % of Total Flow	0.000
Areal Reduction Factor	1.000	MADD Factor * 10m³/ha Storage	0.000
Hot Start (mins)	0	Inlet Coefficient	0.800
Hot Start Level (mm)	0	Flow per Person per Day (l/per/day)	0.000
Manhole Headloss Coeff (Global)	0.500	Run Time (mins)	60
Foul Sewage per hectare (l/s)	0.000	Output Interval (mins)	1


Number of Input Hydrographs 0    Number of Offline Controls 0    Number of Time/Area Diagrams 0  
Number of Online Controls 1    Number of Storage Structures 4    Number of Real Time Controls 0

Synthetic Rainfall Details

BSP Consulting		Page 4
12 Oxford Street Nottingham NG1 5BG	22-0364 Former Woodland Hotel Haverhill	
Date 30/01/2024 File 240125_Surface Water Cal...	Designed by FE Checked by PN	
Innovyze	Network 2020.1.3	

Simulation Criteria for Storm

Rainfall Model	FSR	Profile Type	Summer
Return Period (years)	100	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	20.800	Storm Duration (mins)	30
Ratio R	0.418		

BSP Consulting		Page 5
12 Oxford Street Nottingham NG1 5BG	22-0364 Former Woodland Hotel Haverhill	
Date 30/01/2024 File 240125_Surface Water Cal...	Designed by FE Checked by PN	
Innovyze	Network 2020.1.3	

Online Controls for Storm


Hydro-Brake® Optimum Manhole: SW MH16, DS/PN: 1.007, Volume (m<sup>3</sup>): 6.6

Unit Reference	MD-SHE-0071-2500-1290-2500
Design Head (m)	1.290
Design Flow (l/s)	2.5
Flush-Flo™	Calculated
Objective	Minimise upstream storage
Application	Surface
Sump Available	Yes
Diameter (mm)	71
Invert Level (m)	66.185
Minimum Outlet Pipe Diameter (mm)	100
Suggested Manhole Diameter (mm)	1200

Control Points	Head (m)	Flow (l/s)	Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	1.290	2.5	Kick-Flo®	0.635	1.8
Flush-Flo™	0.312	2.2	Mean Flow over Head Range	-	2.1

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	1.8	1.200	2.4	3.000	3.7	7.000	5.5
0.200	2.2	1.400	2.6	3.500	4.0	7.500	5.7
0.300	2.2	1.600	2.8	4.000	4.2	8.000	5.8
0.400	2.2	1.800	2.9	4.500	4.5	8.500	6.0
0.500	2.1	2.000	3.1	5.000	4.7	9.000	6.2
0.600	1.9	2.200	3.2	5.500	4.9	9.500	6.3
0.800	2.0	2.400	3.3	6.000	5.1		
1.000	2.2	2.600	3.4	6.500	5.3		

BSP Consulting		Page 6
12 Oxford Street Nottingham NG1 5BG	22-0364 Former Woodland Hotel Haverhill	
Date 30/01/2024	Designed by FE	
File 240125_Surface Water Cal...	Checked by PN	
Innovyze	Network 2020.1.3	

Storage Structures for Storm

Filter Drain Manhole: SW MH10, DS/PN: 3.000

Infiltration Coefficient Base (m/hr)	0.00000	Pipe Diameter (m)	0.150
Infiltration Coefficient Side (m/hr)	0.00000	Pipe Depth above Invert (m)	0.000
Safety Factor	2.0	Number of Pipes	1
Porosity	0.30	Slope (1:X)	500.0
Invert Level (m)	69.300	Cap Volume Depth (m)	0.500
Trench Width (m)	0.6	Cap Infiltration Depth (m)	0.000
Trench Length (m)	47.0		

Filter Drain Manhole: SW MH14, DS/PN: 4.000

Infiltration Coefficient Base (m/hr)	0.00000	Pipe Diameter (m)	0.150
Infiltration Coefficient Side (m/hr)	0.00000	Pipe Depth above Invert (m)	0.000
Safety Factor	2.0	Number of Pipes	1
Porosity	0.30	Slope (1:X)	500.0
Invert Level (m)	68.270	Cap Volume Depth (m)	0.500
Trench Width (m)	0.6	Cap Infiltration Depth (m)	0.000
Trench Length (m)	41.0		


Filter Drain Manhole: SW MH15, DS/PN: 5.000

Infiltration Coefficient Base (m/hr)	0.00000	Pipe Diameter (m)	0.150
Infiltration Coefficient Side (m/hr)	0.00000	Pipe Depth above Invert (m)	0.000
Safety Factor	2.0	Number of Pipes	1
Porosity	0.30	Slope (1:X)	500.0
Invert Level (m)	68.130	Cap Volume Depth (m)	0.500
Trench Width (m)	0.6	Cap Infiltration Depth (m)	0.000
Trench Length (m)	33.7		

Tank or Pond Manhole: SW TANK, DS/PN: 1.006

Invert Level (m) 66.275

Depth (m)	Area (m <sup>2</sup> )	Depth (m)	Area (m <sup>2</sup> )	Depth (m)	Area (m <sup>2</sup> )
0.000	230.0	1.200	230.0	1.201	0.0

BSP Consulting		Page 7
12 Oxford Street Nottingham NG1 5BG	22-0364 Former Woodland Hotel Haverhill	
Date 30/01/2024 File 240125_Surface Water Cal...	Designed by FE Checked by PN	
Innovyze	Network 2020.1.3	

1 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

Simulation Criteria

Areal Reduction Factor 1.000    Additional Flow - % of Total Flow 0.000  
Hot Start (mins) 0    MADD Factor \* 10m<sup>3</sup>/ha Storage 0.000  
Hot Start Level (mm) 0    Inlet Coefficient 0.800  
Manhole Headloss Coeff (Global) 0.500    Flow per Person per Day (l/per/day) 0.000  
Foul Sewage per hectare (l/s) 0.000


Number of Input Hydrographs 0    Number of Offline Controls 0    Number of Time/Area Diagrams 0  
Number of Online Controls 1    Number of Storage Structures 4    Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model    FSR    Ratio R 0.417  
Region England and Wales Cv (Summer) 0.750  
M5-60 (mm)    20.800 Cv (Winter) 0.840  
  
Margin for Flood Risk Warning (mm)    300.0  
Analysis Timestep 2.5 Second Increment (Extended)  
DTS Status    ON  
DVD Status    ON  
Inertia Status    ON

Profile(s)    Summer and Winter  
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720,  
960, 1440, 2160, 2880, 4320, 5760, 7200, 8640,  
10080  
Return Period(s) (years)    1, 30, 100  
Climate Change (%)    0, 35, 45


PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow	Overflow Act.	Water Level (m)
1.000	SW RE01	15 Winter	1	+0%					73.384
1.001	SW MH01	15 Winter	1	+0%					71.084
1.002	SW MH02	15 Winter	1	+0%					70.822
1.003	SW MH03	15 Winter	1	+0%	100/15 Summer				69.351
1.004	SW MH04	15 Winter	1	+0%	100/15 Summer				69.123
2.000	SW RE02	15 Winter	1	+0%					73.671
2.001	SW MH05	15 Winter	1	+0%					73.328
2.002	SW MH06	15 Winter	1	+0%					73.027
2.003	SW MH07	15 Winter	1	+0%					72.539
2.004	SW MH08	15 Winter	1	+0%	30/15 Summer				70.310
2.005	SW MH09	15 Winter	1	+0%					70.303
3.000	SW MH10	15 Winter	1	+0%	30/15 Summer				68.949
2.006	SW MH11	15 Winter	1	+0%	30/15 Summer				68.834

BSP Consulting		Page 8
12 Oxford Street Nottingham NG1 5BG	22-0364 Former Woodland Hotel Haverhill	
Date 30/01/2024 File 240125_Surface Water Cal...	Designed by FE Checked by PN	
Innovyze	Network 2020.1.3	

1 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

PN	US/MH Name	Surcharged		Flooded		Flow / Overflow Cap. (l/s)	Half Drain Time (mins)	Pipe Flow (l/s)	Level Status	Exceeded
		Depth (m)	Volume (m <sup>3</sup> )	Flow / Overflow Cap. (l/s)	Flow / Overflow Cap. (l/s)					
1.000	SW RE01	-0.116	0.000	0.12				5.2	OK	
1.001	SW MH01	-0.106	0.000	0.19				5.1	OK	
1.002	SW MH02	-0.178	0.000	0.10				9.4	OK	
1.003	SW MH03	-0.169	0.000	0.14				9.4	OK	
1.004	SW MH04	-0.157	0.000	0.20				16.6	OK	
2.000	SW RE02	-0.119	0.000	0.09				2.4	OK	
2.001	SW MH05	-0.119	0.000	0.09				2.3	OK	
2.002	SW MH06	-0.169	0.000	0.14				8.8	OK	
2.003	SW MH07	-0.187	0.000	0.07				8.8	OK	
2.004	SW MH08	-0.072	0.000	0.30				8.8	OK	
2.005	SW MH09	-0.177	0.000	0.10				11.0	OK	
3.000	SW MH10	-0.051	0.000	0.76			6	9.4	OK	
2.006	SW MH11	-0.118	0.000	0.45				21.1	OK	




BSP Consulting		Page 9
12 Oxford Street Nottingham NG1 5BG	22-0364 Former Woodland Hotel Haverhill	
Date 30/01/2024 File 240125_Surface Water Cal...	Designed by FE Checked by PN	
Innovyze	Network 2020.1.3	

1 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow	Overflow Act.	Water Level (m)
2.007	SW MH12	15	Winter	1	+0%	100/15	Summer		68.690
1.005	SW MH13	15	Winter	1	+0%	30/15	Summer		68.168
4.000	SW MH14	15	Winter	1	+0%				67.708
5.000	SW MH15	15	Winter	1	+0%				67.725
1.006	SW TANK	180	Winter	1	+0%	30/15	Summer		66.465
1.007	SW MH16	240	Winter	1	+0%	1/15	Summer		66.477
1.008	SW MH17	960	Winter	1	+0%				65.777
1.009	SW MH18	180	Summer	1	+0%				65.572
1.010	SW MH19	960	Summer	1	+0%				65.022
1.011	SW MH20	180	Summer	1	+0%				62.173
1.012	SW MH21	180	Winter	1	+0%				59.848

PN	US/MH Name	Surcharged Depth (m)	Flooded Volume (m³)	Flow / Cap. (l/s)	Overflow (l/s)	Half Drain Time (mins)	Pipe Flow (l/s)	Status	Level Exceeded
2.007	SW MH12	-0.154	0.000	0.22			22.1	OK	
1.005	SW MH13	-0.140	0.000	0.30			38.9	OK	
4.000	SW MH14	-0.105	0.000	0.19		6	7.1	OK	
5.000	SW MH15	-0.105	0.000	0.20		6	5.3	OK	
1.006	SW TANK	-0.035	0.000	0.07			3.1	OK	
1.007	SW MH16	0.142	0.000	0.06			2.1	SURCHARGED	
1.008	SW MH17	-0.123	0.000	0.07			2.1	OK	
1.009	SW MH18	-0.128	0.000	0.05			2.1	OK	
1.010	SW MH19	-0.128	0.000	0.05			2.1	OK	
1.011	SW MH20	-0.127	0.000	0.06			2.1	OK	
1.012	SW MH21	-0.112	0.000	0.15			2.1	OK	

BSP Consulting		Page 10
12 Oxford Street Nottingham NG1 5BG	22-0364 Former Woodland Hotel Haverhill	
Date 30/01/2024 File 240125_Surface Water Cal...	Designed by FE Checked by PN	
Innovyze	Network 2020.1.3	

30 year Return Period Summary of Critical Results by Maximum Level (Rank 1)  
for Storm

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m <sup>3</sup> /ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		


Number of Input Hydrographs 0    Number of Offline Controls 0    Number of Time/Area Diagrams 0  
Number of Online Controls 1    Number of Storage Structures 4    Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.417
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	20.800	Cv (Winter)	0.840
Margin for Flood Risk Warning (mm)			300.0
Analysis Timestep	2.5 Second Increment (Extended)		
DTS Status			ON
DVD Status			ON
Inertia Status			ON


Profile(s)		Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440, 2160, 2880, 4320, 5760, 7200, 8640, 10080	
Return Period(s) (years)		1, 30, 100
Climate Change (%)		0, 35, 45

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow	Overflow Act.	Water Level (m)
1.000	SW RE01	15 Winter	30	+35%					73.415
1.001	SW MH01	15 Winter	30	+35%					71.127
1.002	SW MH02	15 Winter	30	+35%					70.868
1.003	SW MH03	15 Winter	30	+35%	100/15 Summer				69.410
1.004	SW MH04	15 Winter	30	+35%	100/15 Summer				69.206
2.000	SW RE02	15 Winter	30	+35%					73.697
2.001	SW MH05	15 Winter	30	+35%					73.354
2.002	SW MH06	15 Winter	30	+35%					73.090
2.003	SW MH07	15 Winter	30	+35%					72.580
2.004	SW MH08	15 Winter	30	+35%	30/15 Summer				70.428
2.005	SW MH09	15 Winter	30	+35%					70.354
3.000	SW MH10	15 Winter	30	+35%	30/15 Summer				69.377
2.006	SW MH11	15 Winter	30	+35%	30/15 Summer				69.119

BSP Consulting		Page 11
12 Oxford Street Nottingham NG1 5BG	22-0364 Former Woodland Hotel Haverhill	
Date 30/01/2024 File 240125_Surface Water Cal...	Designed by FE Checked by PN	
Innovyze	Network 2020.1.3	

30 year Return Period Summary of Critical Results by Maximum Level (Rank 1)  
for Storm


PN	US/MH Name	Surcharged		Flow / Cap.	Overflow (l/s)	Half Drain Time (mins)	Pipe Flow (l/s)	Status	Level Exceeded
		Depth (m)	Volume (m <sup>3</sup> )						
1.000	SW RE01	-0.085	0.000	0.39			17.1	OK	
1.001	SW MH01	-0.063	0.000	0.62			17.0	OK	
1.002	SW MH02	-0.132	0.000	0.36			35.1	OK	
1.003	SW MH03	-0.110	0.000	0.51			34.9	OK	
1.004	SW MH04	-0.074	0.000	0.77			65.0	OK	
2.000	SW RE02	-0.093	0.000	0.30			7.8	OK	
2.001	SW MH05	-0.093	0.000	0.31			7.7	OK	
2.002	SW MH06	-0.106	0.000	0.54			34.8	OK	
2.003	SW MH07	-0.146	0.000	0.27			34.7	OK	
2.004	SW MH08	0.046	0.000	1.16			34.7	SURCHARGED	
2.005	SW MH09	-0.126	0.000	0.40			43.4	OK	
3.000	SW MH10	0.377	0.000	2.47		2	30.5	SURCHARGED	
2.006	SW MH11	0.167	0.000	1.61			74.3	SURCHARGED	

BSP Consulting		Page 12
12 Oxford Street Nottingham NG1 5BG	22-0364 Former Woodland Hotel Haverhill	
Date 30/01/2024 File 240125_Surface Water Cal...	Designed by FE Checked by PN	
Innovyze	Network 2020.1.3	

30 year Return Period Summary of Critical Results by Maximum Level (Rank 1)  
for Storm

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow	Overflow Act.	Water Level (m)
2.007	SW MH12	15 Winter	30	+35%	100/15 Summer				68.787
1.005	SW MH13	15 Winter	30	+35%	30/15 Summer				68.484
4.000	SW MH14	15 Winter	30	+35%					67.751
5.000	SW MH15	15 Winter	30	+35%					67.770
1.006	SW TANK	480 Winter	30	+35%	30/15 Summer				67.038
1.007	SW MH16	480 Winter	30	+35%	1/15 Summer				67.030
1.008	SW MH17	480 Summer	30	+35%					65.778
1.009	SW MH18	240 Winter	30	+35%					65.572
1.010	SW MH19	30 Summer	30	+35%					65.022
1.011	SW MH20	360 Winter	30	+35%					62.173
1.012	SW MH21	480 Summer	30	+35%					59.849

PN	US/MH Name	Surcharged Depth (m)	Flooded Volume (m³)	Flow / Cap. (l/s)	Overflow (l/s)	Half Drain Time (mins)	Pipe Flow (l/s)	Status	Level Exceeded
2.007	SW MH12	-0.057	0.000	0.77			78.5	OK	
1.005	SW MH13	0.176	0.000	1.10			141.2	SURCHARGED	
4.000	SW MH14	-0.062	0.000	0.64		6	23.5	OK	
5.000	SW MH15	-0.060	0.000	0.66		6	17.6	OK	
1.006	SW TANK	0.538	0.000	0.08			3.5	SURCHARGED	
1.007	SW MH16	0.695	0.000	0.06			2.2	SURCHARGED	
1.008	SW MH17	-0.122	0.000	0.08			2.2	OK	
1.009	SW MH18	-0.128	0.000	0.05			2.2	OK	
1.010	SW MH19	-0.128	0.000	0.05			2.2	OK	
1.011	SW MH20	-0.127	0.000	0.06			2.2	OK	
1.012	SW MH21	-0.111	0.000	0.15			2.2	OK	

BSP Consulting		Page 13
12 Oxford Street Nottingham NG1 5BG	22-0364 Former Woodland Hotel Haverhill	
Date 30/01/2024 File 240125_Surface Water Cal...	Designed by FE Checked by PN	
Innovyze	Network 2020.1.3	

100 year Return Period Summary of Critical Results by Maximum Level (Rank 1)  
for Storm

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m <sup>3</sup> /ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		


Number of Input Hydrographs 0    Number of Offline Controls 0    Number of Time/Area Diagrams 0  
Number of Online Controls 1    Number of Storage Structures 4    Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.417
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	20.800	Cv (Winter)	0.840
Margin for Flood Risk Warning (mm)			300.0
Analysis Timestep	2.5 Second Increment (Extended)		
DTS Status			ON
DVD Status			ON
Inertia Status			ON


Profile(s)		Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440, 2160, 2880, 4320, 5760, 7200, 8640, 10080	
Return Period(s) (years)		1, 30, 100
Climate Change (%)		0, 35, 45

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow	Overflow Act.	Water Level (m)
1.000	SW RE01	15 Winter	100	+45%					73.430
1.001	SW MH01	15 Winter	100	+45%					71.150
1.002	SW MH02	15 Winter	100	+45%					70.888
1.003	SW MH03	15 Winter	100	+45%	100/15 Summer				69.965
1.004	SW MH04	15 Winter	100	+45%	100/15 Summer				69.775
2.000	SW RE02	15 Winter	100	+45%					73.708
2.001	SW MH05	15 Winter	100	+45%					73.366
2.002	SW MH06	15 Winter	100	+45%					73.119
2.003	SW MH07	15 Winter	100	+45%					72.596
2.004	SW MH08	15 Winter	100	+45%	30/15 Summer				70.498
2.005	SW MH09	15 Winter	100	+45%					70.376
3.000	SW MH10	15 Winter	100	+45%	30/15 Summer				69.827
2.006	SW MH11	15 Winter	100	+45%	30/15 Summer				69.578

BSP Consulting		Page 14
12 Oxford Street Nottingham NG1 5BG	22-0364 Former Woodland Hotel Haverhill	
Date 30/01/2024 File 240125_Surface Water Cal...	Designed by FE Checked by PN	
Innovyze	Network 2020.1.3	

100 year Return Period Summary of Critical Results by Maximum Level (Rank 1)  
for Storm

PN	US/MH Name	Surcharged		Flow / Cap.	Overflow (l/s)	Half Drain Time (mins)	Pipe Flow (l/s)	Status	Level Exceeded
		Depth (m)	Volume (m <sup>3</sup> )						
1.000	SW RE01	-0.070	0.000	0.55			23.9	OK	
1.001	SW MH01	-0.040	0.000	0.87			23.7	OK	
1.002	SW MH02	-0.112	0.000	0.50			49.0	OK	
1.003	SW MH03	0.445	0.000	0.68			47.0	FLOOD RISK	
1.004	SW MH04	0.495	0.000	0.97			81.7	FLOOD RISK	
2.000	SW RE02	-0.082	0.000	0.42			10.9	OK	
2.001	SW MH05	-0.081	0.000	0.43			10.8	OK	
2.002	SW MH06	-0.077	0.000	0.76			48.6	OK	
2.003	SW MH07	-0.130	0.000	0.37			48.5	OK	
2.004	SW MH08	0.116	0.000	1.62			48.4	SURCHARGED	
2.005	SW MH09	-0.104	0.000	0.56			60.6	OK	
3.000	SW MH10	0.827	0.000	3.42		4	42.3	FLOOD RISK	
2.006	SW MH11	0.626	0.000	1.74			80.6	SURCHARGED	

BSP Consulting		Page 15
12 Oxford Street Nottingham NG1 5BG	22-0364 Former Woodland Hotel Haverhill	
Date 30/01/2024 File 240125_Surface Water Cal...	Designed by FE Checked by PN	
Innovyze	Network 2020.1.3	

100 year Return Period Summary of Critical Results by Maximum Level (Rank 1)  
for Storm

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow	Overflow Act.	Water Level (m)
2.007	SW MH12	15 Winter	100	+45%	100/15 Summer				69.250
1.005	SW MH13	15 Winter	100	+45%	30/15 Summer				68.871
4.000	SW MH14	15 Winter	100	+45%					67.775
5.000	SW MH15	15 Winter	100	+45%					67.794
1.006	SW TANK	480 Winter	100	+45%	30/15 Summer				67.398
1.007	SW MH16	600 Winter	100	+45%	1/15 Summer				67.399
1.008	SW MH17	480 Winter	100	+45%					65.780
1.009	SW MH18	480 Winter	100	+45%					65.574
1.010	SW MH19	480 Winter	100	+45%					65.023
1.011	SW MH20	480 Winter	100	+45%					62.175
1.012	SW MH21	480 Winter	100	+45%					59.852

PN	US/MH Name	Surcharged Depth (m)	Flooded Volume (m³)	Flow / Overflow Cap. (l/s)	Half Drain Time (mins)	Pipe Flow (l/s)	Status	Level Exceeded
2.007	SW MH12	0.406	0.000	0.84		85.2	SURCHARGED	
1.005	SW MH13	0.563	0.000	1.29		166.4	SURCHARGED	
4.000	SW MH14	-0.038	0.000	0.90	6	32.8	OK	
5.000	SW MH15	-0.036	0.000	0.92	6	24.6	OK	
1.006	SW TANK	0.898	0.000	0.08		3.4	SURCHARGED	
1.007	SW MH16	1.064	0.000	0.07		2.4	SURCHARGED	
1.008	SW MH17	-0.120	0.000	0.09		2.4	OK	
1.009	SW MH18	-0.126	0.000	0.06		2.4	OK	
1.010	SW MH19	-0.127	0.000	0.06		2.4	OK	
1.011	SW MH20	-0.125	0.000	0.06		2.4	OK	
1.012	SW MH21	-0.108	0.000	0.17		2.4	OK	