

Consultee Comments for Planning Application

DCON(I)/15/2151

Application Summary

Application Number: DCON(I)/15/2151

Address: Land Ne Haverhill Wilsey Road Little Wratting Suffolk

Proposal: Application to Discharge Conditions 4 (Updated survey information), 6 (waste and recycling), 7 (Landscape and Ecological Management Plan), 8 (Landscape), 15 (Open space strategy), 28 (Garage /parking provision), 30 (Travel Plan - Residential), 37 (foul water strategy), 40 (Arboricultural method statement), 42 (Ecological implementation strategy), and 45 (Biodiversity monitoring) parcel A1, A2 and A8 of application DC/15/2151/OUT

Case Officer: Penny Mills

Consultee Details

Name: Ms Waste Management

Address: West Suffolk Council Depot, Olding Road, Bury St Edmunds, Suffolk IP33 3TA

Email: Not Available

On Behalf Of: Waste Management Operations Manager

Comments

The distances that the refuse crews will have to drag the bins to the freighters from the bin collection points is too far.

In the Suffolk Waste Partnership Waste Technical Guidance for Residential and Commercial Developments Feb 2019 we state that

Collection crews should not have to carry individual waste containers or move wheeled containers in order to facilitate their collection.

In addition, we state that for bin collection points

The maximum distances that any one household should normally be required to move a receptacle (to a bin collection point) will be 50m.

Could the bin collection points please be relocated to fit in with these guidelines.