


REPRODUCED FROM ORDNANCE SURVEY MAPS WITH PERMISSION FROM THE CONTROLLER OF HM STATIONERY OFFICE. CROWN COPYRIGHT RESERVED. LICENCE No. 100023422 2007.

- GENERAL NOTES**
- DO NOT SCALE FROM THIS DRAWING.
 - ALL DIMENSIONS ARE IN MILLIMETRES UNLESS NOTED OTHERWISE.
 - ALL LEVELS ARE IN METRES RELATIVE TO ORDNANCE DATUM UNLESS NOTED OTHERWISE.
 - THIS DRAWING HAS BEEN BASED UPON SURVEY / OS INFORMATION SUPPLIED BY INTERLOCKS SURVEYS LIMITED. ROYAL HASKONING DHV SHALL NOT BE LIABLE FOR ANY INACCURACY OR DEFICIENCIES ARISING FROM IT.
 - THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT DRAWINGS.
 - ALL MATERIALS AND WORKMANSHIP WILL BE AS SPECIFIED IN THE SPECIFICATION UNLESS NOTED OTHERWISE.
 - ALL LEVELS, DIMENSIONS, AND LOCATIONS ARE TO BE CHECKED BY THE MAIN CONTRACTOR PRIOR TO COMMENCEMENT OF ANY WORK ON SITE.

<p>Proposed Column: 5m galvanneal tubular steel column Lantern: Philips Micro Luma DX70 4600 Outside: 300mm Lumen Output: 4.6klm Candela file: Luma Micro_BSPN15_DX70_4600_20LED_S.15_CLO_L50_NW.nw</p>	<p>Proposed Column: 5m galvanneal tubular steel column Lantern: Philips Micro Luma DX70 3400 Outside: 300mm Lumen Output: 3.4klm Candela file: Luma Micro_BSPN15_DX70_3400_20LED_S.15_CLO_L50_NW.nw</p>	<p>Proposed Column: 5m galvanneal tubular steel column Lantern: Philips Micro Luma DM10 1200 Outside: 300mm Lumen Output: 1.2klm Candela file: Luma Micro_BSPN15_DM10_1200_4LED_S.15_CLO_L50_NW.nw</p>	<p>Proposed Column: 5m galvanneal tubular steel column Lantern: Philips Micro Luma DM10 2400 Outside: 300mm Lumen Output: 2.4klm Candela file: Luma Micro_BSPN15_DM10_2400_10LED_S.15_CLO_L50_NW.nw</p>	<p>Proposed Column: 5m galvanneal tubular steel column Lantern: Philips Micro Luma DM10 2400 Outside: 300mm Lumen Output: 2.4klm Candela file: Luma Micro_BSPN15_DM10_2400_10LED_S.15_CLO_L50_NW.nw</p>	<p>Proposed Column: 5m galvanneal tubular steel column Lantern: Philips Micro Luma DM10 2400 Outside: 300mm Lumen Output: 2.4klm Candela file: Luma Micro_BSPN15_DM10_2400_10LED_S.15_CLO_L50_NW.nw</p>
--	--	---	--	--	--



TO: []	DATE: []	DESCRIPTION: []	BY: []	CHK: []	APP: []
REVISIONS					
DRAWING STATUS: TENDER					



PROJECT: GREAT WILSBY PARK	TITLE: STREET LIGHTING LAYOUT
DATE: MAY-19	SCALE: AS SHOWN
DRAWN: MCP	CHECKED: PV
APPROVED: DJ	PROJECT NUMBER: PB8301
DRAWING NO: PB8301-RHD-DE--DR-D-1302	REVISION: TO

Royal HaskoningDHV
Enhancing Society Together

Portland Street, Manchester, M1 3JF
Email: info@haskoningdhv.com
Website: www.haskoningdhv.com

- NOTES**
- ALL WIRING INCLUDING COMPONENT LABELLING TO BE IN ACCORDANCE WITH BS7671.
 - PRIOR TO EXCAVATION WORKS THE INSTALLATION CONTRACTOR MUST BE AWARE OF UNDERGROUND SERVICES OR HAZARDS WHICH MAY BE ENCOUNTERED IN THE INSTALLATION OF THE LIGHTING SYSTEM. ADVICE SHOULD BE SOUGHT FROM THE DEVELOPER'S ENGINEERING REPRESENTATIVE.
 - THE INSTALLATION CONTRACTOR MUST BE AWARE OF ANY OVERHEAD OBSTRUCTIONS. ADVICE SHOULD BE SOUGHT FROM THE DEVELOPER'S ENGINEERING REPRESENTATIVE.
 - ALL COLUMN DOORS SHALL FACE AWAY FROM ONCOMING TRAFFIC UNLESS ACCESS IS RESTRICTED.
 - UNTIL TECHNICAL APPROVAL HAS BEEN OBTAINED FROM THE RELEVANT ADOPTING AUTHORITY, IT SHOULD BE UNDERSTOOD THAT ALL DRAWINGS ISSUED ARE PRELIMINARY AND NOT FOR CONSTRUCTION. SHOULD THE CONTRACTOR COMMENCE SITE WORK PRIOR TO APPROVAL BEING GIVEN, IT IS ENTIRELY AT HIS OWN RISK.
 - THE MAINTENANCE FACTOR IS ESTIMATED AND IS SUBJECT TO CONFIRMATION BY THE ADOPTING AUTHORITY / AUTHORITIES.