

Note & Key

Plot numbers updated, Fibrenest note updated

PERSIMMON

Date:

Mar'21

Checked By:

and intercom system added

Rev Description

Scale@A1:

Drawn By:

1:50 & 1:100

045-T-170.2

04.08.21

Date

Ву

External Doors, Double glazed GRP with a timber or plastic frame, colour see site specification. Front door to have

Install vapour control layer between insulation board and plasterboard ceiling finish. Roof to achieve 0.20 W/m²K.

accordance with their specification and details and in conjunction with I beam 2nd floor joist package by joist supplier.

White UPVC double glazed argon filled sealed units to achieve minimum 1.3w/m²k. Trickle vents to be positioned in the head member of the window to achieve background ventilation rates as follows: Habitable rooms, equivalent area min

Patio Doors, UPVC double glazed argon filled sealed units to achieve minimum 1.3w/m²k. Colour see site specification.

Internal Doors See Site Specification

**Electrical Legend** 

Smoke Detector

(HD) Heat Detector

Pendant Light Batten Light

Wall Light

Smoke Detector (LD2)

HD Heat Detector (LD2)

Co Carbon Monoxide Detector

Q2 Light Switch (2 - 2 way)

13Amp Double Socket Outlet

13Amp fused switched spur with neon light

at high level and unswitched socket at low

13Amp Fused Switched Spur with neon light

Consume Unit (1350-1450mm above FFL)

Cooker Control Spur with outlet below bench

13Amp Double Socket Outlet at high level

Ceiling Mounted Extract Fan

EF Wall Mounted Extract Fan

require a noted Durgo to be replaced with an SVP.

Use energy efficient bulbs throughout not fittings.

Fitted to ALL properties with gas installations to room with boiler.

59m<sup>2</sup> 2 bed house = 30,000mm<sup>2</sup> (2010 regs DAP 5.1 - max 7m<sup>3</sup>/h/m<sup>2</sup>). All vent rates are EQUIVALENT rates - total min 52,000mm<sup>2</sup>

Typically used in unbroken lengths of concrete brickwork of 6m, positioned as indicated on the drawings. MJ's in

Relevant tick sheets are to be completed for each plot when building to 2006 or later building regulations.

walls. Final foundation depths, sizes and types to SI / schedule and by agreement with BCO on site.

Outer leaf 102mm facing brickwork, 100mm cavity fully filled with 100mm blown fibre insulation, inner leaf 100mm

density 3.5N/mm² blockwork with render system. (See materials Schedule for plot by plot external wall finishes)

include 25mm mineral wool acoustic insulation between studs. Partitions requiring 40db are; bedroom/bedroom,

semi/terrace blocks to be positioned on party wall line, ideally behind RWP, if in doubt ask.

**Movement Joints - Concrete Brickwork** 

TP Thermostat

Seneral Notes

**Accredited Details** 

Energy Efficient Lighting

room only 1 to be installed.

**Carbon Monoxide Detector** 

**Background Trickle Ventilation** 

dependent upon house type and SAPs Target.

below DPM. Max U-Value 0.20W/m2C.

External Cavity Walls - Traditional

Internal Partition Walls - Traditional

doors between rooms do not apply.

and en-suite's floors above living spaces.

Truss - Warm Roof (Room in a Roof, 2.5 storey)

5000mm². Wet rooms, equivalent area min 2500mm².

First Floor - Traditional

Internal Party Walls - Robust Detail E-WM-17 with edge sealing

to have drywall jointing ready to receive emulsion paint finish.

thick Gproc wallboard on dabs with drywall jointing ready for emulsion paint finish.

Plasterboard behind "wet" tiled areas ie within shower spray area to be moisture resisting.

All leadwork to be in strict accordance with NHBC standards and Lead Association details.

**Ground Floor - Suspended** 

**Construction Notes** 

Intercom system

Fibre Optic Legend

Fibre Broadband inlet.

Fibre Installation

for Electricians'

Fibre Optic Installation

notes and setting out)

(Installation as per Fibre Optic requirement

(Outlet box back to back where adjacent