



**POND 2 (dry)**  
 Bed Level - 83.500m AOD  
 Bank Level - 85.075m AOD  
 Top Water level - 84.775m AOD  
 Maximum Storage Volume - 985m<sup>3</sup>  
 Overall Cut - 2,334m<sup>3</sup>  
 Overall Fill - 167m<sup>3</sup>

**POND 2 (dry)**  
 Bed Level - 83.500m AOD  
 Bank Level - 85.075m AOD  
 Top Water level - 84.775m AOD  
 Maximum Storage Volume - 985m<sup>3</sup>  
 Overall Cut - 2,334m<sup>3</sup>  
 Overall Fill - 167m<sup>3</sup>

**OUTFALL 3 - Catchmer**  
 Maximum outflow rate - 6.3 liter  
 for all storms up to and includi

Rev	Description	Date	Drawn	Checked
B	Revised Pond 2. Top of water level and arrow gradients added.	28.04.21	AG	PMW
A	Tender Issue	01.04.21	PMW	PMW

Drawing Approval Status:-  
 N/A Section 104    N/A Section 38    N/A Section 278

**FOR TENDER**

Wormald Burrows  
Civil Engineering Consultants  
12a - 18a Hitchin Street, Biggleswade, SG18 8AX  
Tel: (01767) 317244    Web: www.wormburp.com    Email: engineer@wormburp.com

Project:  
**Haverhill, Boyton Place**

Drawing Description:  
**Pond 2 Details and Sections**

Client:  
**PERSIMMON**  
 Persimmon Homes (Suffolk) Limited  
 Persimmon House  
 Prion Court  
 Great Blakenham  
 Ipswich IP6 0LW

Drawing Number:  
**E3838/531B**

Client Reference:

Scale:  
 1:250 @ A1  
 1:500 @ A3

Designed By: TJW    Date: 15.05.19  
 Drawn By: JMW    Date: 24.07.19  
 Checked By:

Certified by Afnor UK

©This drawing is Copyright, Wormald Burrows Partnership Limited 2018.