



Planning Applications – Suggested Informative Statements and Conditions Report

If you would like to discuss any of the points in this document please contact us on 03456 066087, Option 1 or email planningliaison@anglianwater.co.uk

AW Site Reference: 159448/1/0085323

Local Planning Authority: St. Edmundsbury District (B)

Site: Land Nw Of Haverhill Anne Sucklings Lane
Little Wratting Suffolk

Proposal: Reserved Matters Application - Submission of details under SE/09/1283 for the infrastructure for Phases 2-6, Comprising of the Internal Estate Roads, Drainage, POS, Landscaping, Sports Pitches and Allotments

Planning application: DC/20/0614/RM

Prepared by: Pre-Development Team

Date: 15 June 2020

ASSETS

Section 1 - Assets Affected

There are assets owned by Anglian Water or those subject to an adoption agreement within or close to the development boundary that may affect the layout of the site. Anglian Water would ask that the following text be included within your Notice should permission be granted.

Anglian Water has assets close to or crossing this site or there are assets subject to an adoption agreement. Therefore the site layout should take this into account and accommodate those assets within either prospectively adoptable highways or public open space. If this is not practicable then the sewers will need to be diverted at the developers cost under Section 185 of the Water Industry Act 1991. or, in the case of apparatus under an adoption agreement, liaise with the owners of the apparatus. It should be noted that the diversion works should normally be completed before development can commence.

The development site is within 15 metres of a sewage pumping station. This asset requires access for maintenance and will have sewerage infrastructure leading to it. For practical reasons therefore it cannot be easily relocated.

Anglian Water consider that dwellings located within 15 metres of the pumping station would place them at risk of nuisance in the form of noise, odour or the general disruption from maintenance work caused by the normal operation of the pumping station.

The site layout should take this into account and accommodate this infrastructure type through a necessary cordon sanitaire, through public space or highway infrastructure to ensure that no development within 15 metres from the boundary of a sewage pumping station if the development is potentially sensitive to noise or other disturbance or to ensure future amenity issues are not created.

WASTEWATER SERVICES

Section 2 - Wastewater Treatment

The foul drainage from this development is in the catchment of Haverhill Water Recycling Centre which currently does not have capacity to treat the flows the development site. Anglian Water are obligated to accept the foul flows from the development with the benefit of planning consent and would therefore take the necessary steps to ensure that there is sufficient treatment capacity should the Planning Authority grant planning permission.

Section 3 - Used Water Network

This response has been based on the following submitted documents: Drainage Strategy Development will lead to an unacceptable risk of flooding downstream. Anglian Water will need to plan effectively for the proposed development, if permission is granted. We will need to work with the applicant to ensure any infrastructure improvements are delivered in line with the development. We need to ensure that the foul water flows from the development are directed to an appropriate point on the sewerage network. This is currently considered to be the 525mm diameter sewer in Withersfield Road; however, further analysis may provide for a closer point of connection to the sewer in Howe Road We therefore request a condition requiring an on-site drainage strategy confirming an acceptable point of connection. **INFORMATIVE** - Notification of intention to connect to the public sewer under S106 of the Water Industry Act Approval and consent will be required by Anglian Water, under the Water Industry Act 1991. Contact Development Services Team 0345 606 6087. **INFORMATIVE** - Protection of existing assets - A public sewer is shown on record plans within the land identified for the proposed development. It appears that development proposals will affect existing public sewers. It is recommended that the applicant contacts Anglian Water Development Services Team for further advice on this matter. Building over existing public sewers will not be permitted (without agreement) from Anglian Water. **INFORMATIVE** - Building near to a public sewer - No building will be permitted within the statutory easement width of 3 metres from the pipeline without agreement from Anglian Water. Please contact Development Services Team on 0345 606 6087. **INFORMATIVE:** The developer should note that the site drainage details submitted have not been approved for the purposes of adoption. If the developer wishes to have the sewers included in a sewer adoption agreement with Anglian Water (under Sections 104 of the Water Industry Act 1991), they should contact our Development Services Team on 0345 606 6087 at the earliest opportunity. Sewers intended for adoption should be designed and constructed in accordance with Sewers for Adoption guide for developers, as supplemented by Anglian Water's requirements.

Section 4 - Surface Water Disposal

The preferred method of surface water disposal would be to a sustainable drainage system (SuDS) with connection to sewer seen as the last option. Building Regulations (part H) on Drainage and Waste Disposal for England includes a surface water drainage hierarchy, with infiltration on site as the preferred disposal option, followed by discharge to watercourse and then connection to a sewer.

Anglian Water has reviewed the submitted documents (Drainage Strategy and Flood Risk Assessment) and can confirm that these are acceptable to us. We require these documents to be listed as approved plans/documents if permission is granted.

Section 5 - Suggested Planning Conditions

Anglian Water would therefore recommend the following planning condition if the Local Planning Authority is mindful to grant planning approval.

Assets Affected (Section 1)

Used Water Sewerage Network (Section 3)

We have no objection subject to the following condition: Condition Prior to the construction above damp proof course, a scheme for on-site foul water drainage works, including connection point and discharge rate, shall be submitted to and approved in writing by the Local Planning Authority. Prior to the occupation of any phase, the foul water drainage works relating to that phase must have been carried out in complete accordance with the approved scheme. Reason To prevent environmental and amenity problems arising from flooding

Surface Water Disposal (Section 4)

No drainage works shall commence until a surface water management strategy has been submitted to and approved in writing by the Local Planning Authority. No hard-standing areas to be constructed until the works have been carried out in accordance with the strategy

FOR THE ATTENTION OF THE APPLICANT - if Section 3 or Section 4 condition has been recommended above, please see below information:

Next steps

Desktop analysis has suggested that the proposed development will lead to an unacceptable risk of flooding downstream. We therefore highly recommend that you engage with Anglian Water at your earliest convenience to develop in consultation with us a feasible drainage strategy.

If you have not done so already, we recommend that you submit a Pre-planning enquiry with our Pre-Development team. This can be completed online at our website <http://www.anglianwater.co.uk/developers/pre-development.aspx>

Once submitted, we will work with you in developing a feasible mitigation solution.

If a foul or surface water condition is applied by the Local Planning Authority to the Decision Notice, we will require a copy of the following information prior to recommending discharging the condition:

Surface water:

- Feasible drainage strategy agreed with Anglian Water detailing the discharge solution, including:
 - Development hectare size
 - Proposed discharge rate (Our minimum discharge rate is 5l/s. The applicant can verify the site's existing 1 in 1 year greenfield run off rate on the following HR Wallingford website -<http://www.uksuds.com/drainage-calculation-tools/greenfield-runoff-rate-estimation> . For Brownfield sites being demolished, the site should be treated as Greenfield. Where this is not practical Anglian Water would assess the roof area of the former development site and subject to capacity, permit the 1 in 1 year calculated rate)
 - Connecting manhole discharge location
- Sufficient evidence to prove that all surface water disposal routes have been explored as detailed in the surface water hierarchy, stipulated in Building Regulations Part H (Our Surface Water Policy can be found on our website)