

St Edmundsbury Borough Council
Planning Department
West Suffolk House
Western Way
Bury St Edmunds
IP33 3YU



Fire Business Support Team
Floor 3, Block 2
Endeavour House
8 Russell Road
Ipswich, Suffolk
IP1 2BX

Your Ref:
Our Ref: FS/F281653
Enquiries to: Angela Kempen
Direct Line: 01473 260588
E-mail: Fire.BusinessSupport@suffolk.gov.uk
Web Address: <http://www.suffolk.gov.uk>

Date: 24/01/2017

Dear Sirs

Flat, The Vixen, Millfields Way, Haverhill CB9 0BJ
Planning Application No: S106 + DC/16/2755/FUL

I refer to the above application.

The plans have been inspected by the Water Officer who has the following comments to make.

Access and Fire Fighting Facilities

Access to buildings for fire appliances and firefighters must meet with the requirements specified in Building Regulations Approved Document B, (Fire Safety), 2006 Edition, incorporating 2010 and 2013 amendments Volume 1 - Part B5, Section 11 dwelling houses, and, similarly, Volume 2, Part B5, Sections 16 and 17 in the case of buildings other than dwelling houses. These requirements may be satisfied with other equivalent standards relating to access for fire fighting, in which case those standards should be quoted in correspondence.

Suffolk Fire and Rescue Service also requires a minimum carrying capacity for hard standing for pumping/high reach appliances of 15/26 tonnes, not 12.5 tonnes as detailed in the Building Regulations 2000 Approved Document B, 2006 Edition, incorporating 2010 and 2013 amendments.

Water Supplies

Suffolk Fire and Rescue Service recommends that fire hydrants be installed within this development on a suitable route for laying hose, i.e. avoiding obstructions. However, it is not possible at this time to determine the number of fire hydrants required for fire fighting purposes. The requirement will be determined at the water planning stage when site plans have been submitted by the water companies.

Continued/


OFFICIAL

Suffolk Fire and Rescue Service recommends that proper consideration be given to the potential life safety, economic, environmental and social benefits derived from the provision of an automatic fire sprinkler system. (Please see sprinkler information enclosed with this letter).

Consultation should be made with the Water Authorities to determine flow rates in all cases.

Should you need any further advice or information on access and fire fighting facilities, you are advised to contact your local Building Control in the first instance. For further advice and information regarding water supplies, please contact the Water Officer at the above headquarters.

Yours faithfully



Mrs A Kempen
Water Officer

Enc: PDL1

Copy: Mr C Read, Radford Homes, Unit A, Homefield Road, Haverhill CB9 8QP
Enc: Sprinkler information

Planningcontributions.admin@suffolk.gov.uk

St Edmundsbury Borough Council
Planning Department
West Suffolk House
Western Way
Bury St Edmunds
IP33 3YU

Fire Business Support Team
Floor 3, Block 2
Endeavour House
8 Russell Road
Ipswich, Suffolk
IP1 2BX

Your Ref:
Our Ref: ENG/AK
Enquiries to: Mrs A Kempen
Direct Line: 01473 260486
E-mail: Angela.Kempen@suffolk.gov.uk
Web Address: www.suffolk.gov.uk

Date: 24 January 2017

Planning Ref: S106 + DC/16/2755/FUL

Dear Sirs

RE: PROVISION OF WATER FOR FIRE FIGHTING
ADDRESS: Flat, The Vixen, Millfields Way, Haverhill CB9 0JB
DESCRIPTION: 18 Flats
NO: HYDRANTS POSSIBLY REQUIRED: May be required

If the Planning Authority is minded to grant approval, the Fire Authority will request that adequate provision is made for fire hydrants, by the imposition of a suitable planning condition at the planning application stage.

If the Fire Authority is not consulted at the planning stage, the Fire Authority will request that fire hydrants be installed retrospectively on major developments if it can be proven that the Fire Authority was not consulted at the initial stage of planning.

The planning condition will carry a life term for the said development and the initiating agent/developer applying for planning approval and must be transferred to new ownership through land transfer or sale should this take place.

Fire hydrant provision will be agreed upon when the water authorities submit water plans to the Water Officer for Suffolk Fire and Rescue Service.

Where a planning condition has been imposed, the provision of fire hydrants will be fully funded by the developer and invoiced accordingly by Suffolk County Council.


Until Suffolk Fire and Rescue Service receive confirmation from the water authority that the installation of the fire hydrant has taken place, the planning condition will not be discharged.

Continued/

OFFICIAL

Should you require any further information or assistance I will be pleased to help.

Yours faithfully



Mrs A Kempen
Water Officer