



Planning Applications – Suggested Informative Statements and Conditions Report

| | |
|---------------------------|---|
| AW Reference: | 00019814 |
| Local Planning Authority: | St. Edmundsbury District (B) |
| Site: | The Vixen Millfields Way Haverhill, HAVERHILL - Haverhill North |
| Proposal: | Change of use to convert and renovate the Vixen Public House (Class A4) to form 18 residential flats (Class C3) and 2 retail, commercial or Offices (Class A1, A2 or B1) and associated external works to remodel and extend the existing car park. |
| Planning Application: | DC/16/2755/FUL |

Prepared by: Sandra Olim

Date: 27 February 2017

If you would like to discuss any of the points in this document please
contact me on 0345 0265 458 or email
planningliaison@anglianwater.co.uk

ASSETS

Section 1 – Assets Affected

- 1.1 Our records show that there are no assets owned by Anglian Water or those subject to an adoption agreement within the development site boundary.

WASTEWATER SERVICES

Section 2 – Wastewater Treatment

- 2.1 The foul drainage from this development is in the catchment of Haverhill Water Recycling Centre that will have available capacity for these flows.

Section 3 – Foul Sewerage Network

- 3.1 The sewerage system at present has available capacity for these flows. If the developer wishes to connect to our sewerage network they should serve notice under Section 106 of the Water Industry Act 1991. We will then advise them of the most suitable point of connection.

Section 4 – Surface Water Disposal

- 4.1 The surface water strategy/flood risk assessment submitted with the planning application relevant to Anglian Water is acceptable.

We request that the agreed strategy is reflected in the planning approval

Section 5 – Trade Effluent

- 5.1 The planning application includes employment/commercial use. To discharge trade effluent from trade premises to a public sewer vested in Anglian Water requires our consent. It is an offence under section 118 of the Water Industry Act 1991 to discharge trade effluent to sewer without consent. Anglian Water would ask that the following text be included within your Notice should permission be granted.

"An application to discharge trade effluent must be made to Anglian Water and must have been obtained before any discharge of trade effluent can be made to the public sewer.

Anglian Water recommends that petrol / oil interceptors be fitted in all car parking/washing/repair facilities. Failure to enforce the effective use of such facilities could result in pollution of the local watercourse and may constitute an offence.

Anglian Water also recommends the installation of a properly maintained fat traps on all catering establishments. Failure to do so may result in this and other properties suffering blocked drains, sewage flooding and consequential environmental and amenity impact and may also constitute an offence under section 111 of the Water Industry Act 1991."

Section 6 – Suggested Planning Conditions

Anglian Water would therefore recommend the following planning condition if the Local Planning Authority is mindful to grant planning approval.

Surface Water Disposal (Section 4)

CONDITION

No hard-standing areas to be constructed until the works have been carried out in accordance with the surface water strategy so approved unless otherwise agreed in writing by the Local Planning Authority.

REASON

To prevent environmental and amenity problems arising from flooding.
