

Consultee Comments for Planning Application

DC/25/1405/HH

Application Summary

Application Number: DC/25/1405/HH

Address: 43 Roman Way Haverhill Suffolk CB9 0NG

Proposal: Householder planning application - Install air source heat pump

Case Officer: Thomas Halliday

Consultee Details

Name: Julie Roberts

Address: West Suffolk House, Western Way, Bury St Edmunds, Suffolk IP33 3YU

Email: Not Available

On Behalf Of: Private Sector Housing And Environmental Health

Comments

The detail provided with this application indicates that the installation fails the MCS020 air source heat pump assessment and therefore does not qualify as permitted development. The application will therefore require the submission of a Noise Impact assessment or the substitution of the air source heat pump proposed with a model with a lower sound power level specification.